



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

**Steel Pipe Manufactured to
ASTM A795 / A795M Schedule 10
Sizes 1 through 10 inch NPS
(See Attached Table for Additional Details)**

Prepared for: Pacific Pipe Public Co, 298. 298/2 Suksawad Road
Prasamutjadee, Samutprakarn 10290, Thailand

Manufacturing Location: Pacific Pipe Public Co, 1/97 Samutsakorn Industrial Estate, Rama II Road
Muang, Samutsakorn 74000, Thailand

Galvanizing Location: Pacific Pipe Public Co, 1/112 Samutsakorn Industrial Estate, Rama II Road
Muang, Samutsakorn 74000, Thailand

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3056074 Approval Granted: January 23, 2017
Revision Request No.: RR208734 Request Accepted: April 20, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'David B. Fuller'.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, in.	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 10 ^{a, d, g, q, r, s}	Thailand	1, 1-1/4, 1-1/2, 2	175	1205	FM Approved
Schedule 10 ^{a, d, q, r}	Thailand	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5	300	2070	FM Approved
Schedule 10 ^{a, d, q, s}	Thailand	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6	300	2070	FM Approved
Schedule 10 ^{a, d, s}	Thailand	8, 10	225	1550	FM Approved

Notes: a - FM Approved for use with FM Approved pipe couplings on rolled grooves
d - When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems
g - FM Approved for use with FM Approved plain-end fittings
q - Manufactured out of ASTM A135 / A135M Grade A
r - Manufactured out of ASTM A135 / A135M Grade B as an alternate material
s - Manufactured out of ASTM A795 / A795M Grade B as an alternate material

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3056074
Revision Request No: RR208734

Approval Granted: January 23, 2017
Request Accepted: April 20, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'David B. Fuller'.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group