

CERTIFICATE OF COMPLIANCE

Certificate Number 20180529-EX15190
Report Reference EX15190-20070416
Issue Date 2018-MAY-29

Issued to: PACIFIC PIPE PUBLIC CO LTD
298 298/2 Soi Klabcharoen 3
Suksawad Rd, Prasamutjadee
Samutprakarn 10290 THAILAND

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE

Schedule 40 (black or galvanized) steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10 and 12 in. sizes as per ASTM A53, Grade A and B, Type E.

Schedule 10 (black or galvanized) steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8 and 10 in. sizes as per ASTM A795 Grade A and B, Type E.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

UL 852, Metallic Sprinkler Pipe for Fire Protection Service
See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

