



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

<u>Pipe Specification</u>	<u>Pipe Schedule</u>	<u>Pipe Size</u>
ASTM A795 / A795M	Schedule 10	1 through 6 inch NPS
ASTM A135 / A135M	Schedule 10	1 through 5 inch NPS
ASTM A53 / A53M	Schedule 40	1 through 12 inch NPS

Prepared for:

Pacific Pipe Public Co Ltd
298, 298/2 Suksawad Rd
Prasamutjadee, Samutprakarn, 10290
Thailand

Galvanized at:

Pacific Pipe Public Co., Ltd.
1/112 Samutsakorn Industrial Estate, Rama II Road
Muang, Samutsakorn, 74000
Thailand

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3050814

Approval Granted: April 10, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne
Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

<u>Pipe Specification</u>	<u>Pipe Schedule</u>	<u>Pipe Size</u>
ASTM A795 / A795M	Schedule 10	1 through 6 inch NPS
ASTM A135 / A135M	Schedule 10	1 through 5 inch NPS
ASTM A53 / A53M	Schedule 40	1 through 12 inch NPS

Prepared for:

Pacific Pipe Public Co Ltd
298, 298/2 Suksawad Rd
Prasamutjadee, Samutprakarn, 10290
Thailand

Manufactured at:

Pacific Pipe Public Co., Ltd.
1/97 Samutsakorn Industrial Estate, Rama II Road
Muang, Samutsakorn, 74000
Thailand

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3050814

Approval Granted: April 10, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group